

DAILY FIELD REPORT

Island Geotechnical Engineering

FILE NO. 222217-TM
DFR NO. 06
PAGE 1 of 1

PROJECT Mahana Estates Lot #34			LOCATION Lahaina, Maui, Hawaii						
CLIENT Dwight Galbi			DATE 6/22/2023	DAY OF WEEK Thursday	WEATHER Sunny				
GENERAL CONTRACTOR Cutting Edge Development Inc. www.cedhawaii.com			CONTRACTOR'S SUPERINTENDENT Brad Fitkin (808)205-8445 brad@cedhawaii.com						
TYPE OF WORK Compaction Testing			PROJECT ENGINEER						
SOURCE AND DESCRIPTION OF FILL MATERIAL Select fill imported from Hawaiian Cement Waikapu			KEY PERSONS CONTACTED Travis MacDonald (808)269-2202						
TEST NO.	TEST LOCATION	ELEVATION (In Feet)	FIELD TESTING			REFERENCE CURVE			COMMENTS
			DRY DEN. (pcf)	MOIST. CONT. (%)	% OF MAX DRY DEN.	COMP CURVE NO.	MAX DRY DEN (PCF)	R.C. Y/N	
16	Garage	151.5'+msl*	128.7	10.1	98.9	2	130.1	N	Pass

DESCRIBE EQUIPMENT USED

Sakai SV544D 12-ton vibratory drum roller

NOTES

Compaction Testing: IGE is onsite at the request of Cutting-Edge Development to perform compaction testing on imported Select Fill from Hawaiian Cements' Waikapu quarry. Placement of material is to ~151.5' +msl* in the Garage pad subgrade. Compaction tests reveal adequate compaction and moisture. *Elevation is provided by the contractor. Contractor began the placement of Select borrow material into main pad area. Sample was brought back to IGE lab for further testing.



COPY SENT TO:

REPORT BY

Tyler Martin. Field Technician

EG=Existing Grade

TBC = Top of Base Course

DL = Drain Line

WL = Water Line

DMH = Drain Manhole

FG = Finishing Grade

TSB = Top of Subgrade

EL = Electrical Line

RC = Rock Correction

CB = Catch Basin

FSG = Finishing Subgrade

Sta = Station

SL = Sewer Line

RW = Retaining Wall

BOF = Bottom of Footing